

A P P R O V A L S ®

Certificate of Suitability

Certificate No.:	SAA231947
Certificate Holder:	Shelly Europe Ltd. 103 Cherni Vrah Blvd., 1407 Sofia, Bulgaria
Regulatory Definition:	Non-Prescribed
Product Description:	Smart Energy Measurement Instrument (Din-Rail mounted, Wi-Fi, LAN, Bluetooth)
Standard/s:	AS 61010.1: 2003(R2016) AS 60669.2.1: 2020 AS/NZS 60669.1:2020
Condition/s:	Nil
Approval Marks:	RCM (In accordance with AS/NZS 4417 and EESS requirements) and SAA231947
Initial Issue Date:	21 May 2024
Expiry Date:	21 May 2029

R. A. NUL

For and on Behalf of SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



CERTIFIED

Issued: 21-05-24 231947 Page 1 of 2



A P P R O V A L S ®

Certificate of Suitability

Model Shelly Pro EM-50

Trade Name Shelly

Rating/Marking

110-240V~ 50/60Hz Max measured current 50A per channel Max switching Voltage 240Vac Max switching current 2A Working temperature: -20 to Max 40°C

A. Nillo

For and on Behalf of SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au



CERTIFIED

Issued: 21-05-24 231947 Page 2 of 2

www.jas-anz.org/register